

TEST RESULTS

Slip resistance - Ramp test
Method DIN 51130:2014

Date of testing : 14/03/2016

Mean angle of acceptance, α_{ges} : 11.3°

Slip resistance classification : R10

Date
16/03/2016


Project number
89209409

Report number
89209409.03en


Article
Floorgraphics film with special
structure printed with solvent ink

Page
3/3

Author:
Mr. J. de Wolff



Review:
Mrs. E. Zwier



All rights reserved.

No part of this report may be reproduced, provided to and/or examined by third parties, and/or published by print, photoprint, microfilm, in electronic form or any other means without the explicit previous written consent of TÜV Rheinland Nederland B.V. The results are based upon the samples received and have not to be representative for the total production. TÜV Rheinland Nederland B.V. had no influence on the sampling.

In case this report was drafted within the context of an assignment to TÜV Rheinland Nederland B.V., the rights and obligations of contracting parties are subject to the General Terms & Conditions for Advisory, Research and Certification assignments to TÜV Rheinland Nederland B.V. and/or the relevant agreement concluded between the contracting parties.

© 2010 TÜV Rheinland Nederland B.V.

(end of report)